Efectis France
ZI Les Nappes
149, route du Marc
F-38630 LES AVENIERES VEYRINS-THUELLIN
Tél: +33 (0)4 37 06 38 11

CERTIFICATE ENGLISH VERSION

ENGLISH VERSION OF THE OFFICIAL FRENCH PROCES-VERBAL N° EFR-21-001683-2

Only the original French edition of this procès-verbal is authentic. Seule l'édition originale en français du présent procès-verbal fait foi.

The French PROCES VERBAL is valid for 5 years starting on May 19th, 2021

Applicant PIERRE FREY

47 Rue des Petits Champs

75001 PARIS

France

Sample reference F3600 PUMORI

Brief description provided by

the applicant

Fabric, with in the mass fire-retardant, made of TREVIRA CS.

Mass per unit area determined by the laboratory

 $90 \text{ g/m}^2 \pm 10\%$

Thickness measured by the

laboratory

0,28 mm ± 10%

Colour COTON

End-use condition Veiling

Standard of tests:

- NF P 92-507 (2004) Building Interior fitting materials Classification according to their reaction to fire
- NF P 92-503 (1995) Reaction to fire tests Electrical burner test used for flexible materials
- NF P 92-504 (1995) Reaction to fire tests Flame persistence test and speed of the spread of flame
- NF P 92-505 (1995) Reaction to fire tests Test used for thermal melting materials Dripping test

Classification obtained in the official Procès Verbal:

M1

Valid for any application for which the product is not subjected to the CE marking.

Durability of the classification (NFP 92-512: 1986): Supposedly unlimited

Taking into account the criteria resulting from the tests described in the test report n°RE EFR-21-BE-001683-2 from May 25th, 2021.

This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.115-27 of the Consumer Code and the Law of June 3rd, 1994.

Efectis France is approved for fire reaction tests according to the Decree of December 29th, 2016 amending the Decree of February 5th, 1959.

Les Avenières Veyrins-Thuellin, on May 25th, 2021