



## Approval of the Trademark Trevira CS®

Pierre Frey  
47, rue des Petits Champs  
75001 Paris  
France

|  |                 |
|--|-----------------|
| <b>Application No.:</b>                    | 220022.1        |
| <b>Date of issue:</b>                      | 22.03.2022      |
| <b>Valid until:</b>                        | 25.02.2027      |
| <b>Article name:</b>                       | F3286 JULIA     |
| <b>End use:</b>                            | Curtains        |
| <b>Square weight (g/m<sup>2</sup>):</b>    | 117             |
| <b>According to customer specification</b> |                 |
| <b>Composition of the raw materials:</b>   | Polyester 100%  |
| <b>Composition of the fabric:</b>          | Trevira CS 100% |

The article F3286 JULIA has been tested under the Trevira trademark application no. 220022 and is granted approval for the trademark Trevira CS® for interior use.

The article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The article meets the requirements for class 1 according to EN 13773.

Thus meets also the requirements according to British Standard BS 5867 part 2 type C.

Thus meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457.

This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Trevira GmbH  
(This document is valid without signature.)