

Pierre Frey 47 Rue des Petits Champs 75001 paris France

our message - reference	our reference	Gent
-	JW/3273	2024-09-19
Cartification report 21/2272		

Certification report 24/32/3

1. Description of the product:

ī

Product type	decorative wall covering consisting of a non-woven backing and a finish composed of a recycled paste (ca. 80-90%) of polyester fibers (ca. 10-20%) and resistance agents to humidity and sizing agents (ca. 3%)
Total mass	150 g/m²
Thickness	0.28 mm

2. Test performed:

ASTM E84 – Standard test method for surface burning characteristics of building materials

Class	flame spread index	smoke developed
l or A	0-25	450 or less

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

CENTEXBEL • textile competence centre • www.centexbel.be GENT • Technologiepark 70 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • gent@centexbel.be VAT • BE 0459.218.289 • IBAN • BE 44 2100 4729 6545 • BIC • GEBABEBB

addressee	our reference	Gent	page
Pierre frey	JW/3273	2024-09-19	2

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

Class	l or A
-------	--------

Specimen adhered to gypsum

The evaluation of this properties is based on the reported results and NFPA Code Classification System.

Related commercial names to this product group	AL – print SAHARA NW – example FP152 AGAFAY
The obtained classification is based on the next test reports	SGS: 3-56664-0 dd 22-07-2024
Validity of the certificate	21-07-2029

Jo Wynendaele, PhD

Consultant Floor and Wall Coverings

Ju y rendele