



## Limited Approval for the Trademark Trevira CS®

Pierre Frey  
47, rue des Petits Champs  
75001 Paris  
France

<b>Application No.:</b>	210484.1
<b>Date of issue:</b>	21.07.2021
<b>Valid until:</b>	15.07.2026
<b>Article name:</b>	F3565 ZERMATT
<b>End use :</b>	Curtains
<b>Square weight (g/m<sup>2</sup>):</b> according to customer specification	110
<b>Composition of the raw materials:</b>	Polyester 100%
<b>Composition of the fabric:</b>	Trevira CS 87% 22 dtex, non-monofilament CS 13%

The article F3565 ZERMATT has been tested under the Trevira trademark application no. 210484 and is granted approval for the trademark Trevira CS® for interior use.  
The article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The article was tested according to EN 1101 and thus also meets the requirements for class 1 according to EN 13773.

Trevira GmbH  
(This document is valid without signature.)