



LABORATOIRE CENTRAL
MESURES PHYSIQUES ET SCIENCES DE L'INCENDIE
SCIENCES DU FEU ET D'ÉLECTRICITÉ

**CLASSIFICATION REPORT OF THE BURNING
BEHAVIOUR OF MATERIALS**

ACCORDING TO ARTICLE 5 OF THE 21ST NOVEMBER 2002 DECREE
(free translation of French classification report n°19/13899)

Valid for 5 years from the 14th of January 2020

CLASSIFICATION REPORT N° 19/13899

Material submitted by : Pierre Frey
47 RUE DES PETITS CHAMPS
BP 56
75001 PARIS

Commercial trademark : I6615 CAPRI II

Brief description : Velvet fabric.

Composition : 100 % Polyester Trevira CS.

Mass per square meter : Around 475 g/m².

Thickness : Around 1,85 mm.

Colours : Various plain colours.

Type of tests : Electric burner and additional tests

Classification : M1

Durability of classement : Not limited a priori

In case of a dispute, the first French edition of this classification report shall prevail.
This report only certifies the characteristics of the tested samples but in no way those of similar products.
This is not a product certification according to the L.115-27 article of the French Consumer Protection Code and the law of 3rd June 1994.

Fait à Paris, le 14/01/2020

Pour le Directeur,
le chef du pôle mesures physiques et sciences de
l'incendie


Jean-Pierre ORAZY



Le responsable technique


Jennifer CHERON

RÉPUBLIQUE FRANÇAISE
Liberté Égalité Fraternité
LABORATOIRE CENTRAL DE LA PRÉFECTURE DE POLICE - 39 bis, rue de Dantzig - 75015 PARIS - Std. 33(0)1 55 76 24 15
<http://www.prefecturedepolice.paris> - mël : pp-labcent@interieur.gouv.fr

La reproduction de ce rapport n'est autorisée que sous la forme de fac-similé photographique intégral.