



LABORATOIRE CENTRAL
MESURES PHYSIQUES ET SCIENCES DE L'INCENDIE
SCIENCES DU FEU ET D'ÉLECTRICITÉ

**CLASSIFICATION REPORT OF THE BURNING
BEHAVIOUR OF MATERIALS**
ACCORDING TO ARTICLE 5 OF THE 21ST NOVEMBER 2002 DECREE
(free translation of French classification report n° 19/8722)
Valid for 5 years from the 13th of August 2019

CLASSIFICATION REPORT N° 19/8722

Material submitted by : Pierre Frey
47 RUE DES PETITS CHAMPS
BP 56
75001 PARIS

Commercial trademark : O7720 SOLA

Brief description : Plain color veiling.

Composition : 100 % Polyester Trévira CS.

Mass : Around 100 grams par square meter.

Thickness : Close to 0,32 millimeter.

Colour : Various.

Type of tests : ELECTRIC BURNER AND ADDITIONNAL TESTS

Classification : **M1**

Durability of classification : **Not limited a priori**

In case of a dispute, the first French edition of this classification report only shall prevail.
This report only certifies the characteristics of the tested samples but in no way those of similar products.
This is not a product certification according to the L.115-27 article of the French Consumer Protection Code and to the law of 3rd June 1994.

Fait à Paris, le 14/08/2019

Pour le Directeur,
le chef du pôle mesures physiques et sciences de
l'incendie


Jean-Pierre ORAZY



Le responsable technique


Jennifer CHERON