

ENGLISH VERSION OF THE OFFICIAL FRENCH PROCÈS-VERBAL N° EFR-21-000055C

Only the original French edition of this procès-verbal shall be authentic.
Seule l'édition originale en français du présent procès-verbal fait foi.

The French PROCES VERBAL is valid for 5 years starting on February 23rd, 2021

Applicant	PIERRE FREY 47 Rue des Petits Champs 75002 PARIS France
Sample reference	F3053 DORIS
Brief description provided by the applicant	Fabric, with in the mass fire retardant, made of TREVIRA CS polyester.
Mass per unit area determined by the laboratory	45 g/m ² ± 10%
Thickness measured by the laboratory	0,18 mm ± 10%
Color	White
End-use condition	Decoration fabric and Curtains

Standard of tests:

- **NF P 92-507 (2004)** - Building - Interior fitting materials - Classification according to their reaction to fire
- **NF P 92-503 (1995)** - Reaction to fire tests - Electrical burner test used for flexible materials
- **NF P 92-504 (1995)** - Reaction to fire tests - Flame persistence test and speed of the spread of flame
- **NF P 92-505 (1995)** - Reaction to fire tests - Test used for thermal melting materials - Dripping test

Classification obtained in the official Procès Verbal:

M1

Valid for any application for which the product is not subjected to the CE marking.

Durability of the classification (NFP 92-512 : 1986): Supposedly unlimited

Taking into account the criteria resulting from the tests described in the test report n°EFR-21-BE-000055C from March 12th, 2021.

This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.115-27 of the Consumer Code and the Law of June 3rd, 1994.

Efectis France is approved for fire reaction tests according to the Decree of December 29th, 2016 amending the Decree of February 5th, 1959.

Les Avenières Veyrins-Thuellin, on March 12th, 2021