



Approval of the Trademark Trevira CS®

Pierre Frey
47, rue des Petits Champs
75001 Paris
France

Application No.:	210413.1
Date of issue:	11.06.2021
Valid until:	11.06.2026
Article name:	F3583 MONT YARI
End use:	Curtains
Square weight (g/m²):	80
According to customer specification	
Composition of the raw materials:	Polyester 100%
Composition of the fabric:	Trevira CS 100%

The article F3583 MONT YARI has been tested under the Trevira trademark application no. 210413 and is granted approval for the trademark Trevira CS® for interior use.

The article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

Trevira GmbH
(This document is valid without signature.)