

**MATERIAL REACTION TO FIRE CLASSIFICATION REPORT  
PREPARED IN COMPLIANCE WITH AMENDED 5 OF THE FRENCH HOME OFFICE REGULATION  
REGULATION DATED NOVEMBER 21ST, 2002 (OFFICIAL GAZETTE DATED DECEMBER 31, 2002)**

Delivered as an extension of certificate n°22-02603 L, valid until November 8th 2027 expiration date of the first PV

**CERTIFICATE N° 22-02603-2 L**

And 0 Appendix of 0 pages

**MATERIAL presented by:**

PIERRE FREY  
47, rue des Petits Champs  
75001 Paris  
France

**TRADE NAME:**

1 O7844 POITOU  
1450/1

**BRIEF DESCRIPTION:**

Net fabric 100% polyester made of inherent fire resistant polyester FR and standard polyester

Nominal surface weight : 75 g/m<sup>2</sup>  
Nominal thickness : 0.15 mm  
Colours : Various

**TEST REPORT :**

N° 22-02603 E1V1 on the November 8th 2022

**TESTS :**

Electrical burner test  
Flame persistence test  
Dripping test

**CLASSIFICATION**

**M1**

**Classification valid for any application for which the product is not subjected  
to the CE marking of the Construction products**

**CLASSIFICATION DURATION (article 5 of appendix 2) :**

unlimited unless otherwise specified

given the criteria resulting from the tests described in the enclosed test report.

The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law dated March 14, 2016.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

**Issued in Lyon, France, on the January 18th 2023**



Olivier PALLAS  
Tests and Trials Engineer