



Approval of the Trademark Trevira CS®

Pierre Frey
47, rue des Petits Champs
75001 Paris
France

Application No.:	210354.1
Date of issue:	14.06.2021
Valid until:	27.05.2026
Article name:	F3601 BROAD PEAK
End use:	Drapes
Square weight (g/m²):	79
<i>According to customer specification</i>	
Composition of the raw materials:	Polyester 100%
Composition of the fabric:	Trevira CS 100%

The article F3601 BROAD PEAK has been tested under the Trevira trademark application no. 210354 and is granted approval for the trademark Trevira CS® for interior use.
The article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.
The article meets the requirements for class 1 according to EN 13773.
Thus meets also the requirements according to British Standard BS 5867 part 2 type C.
Thus meets also the requirements for class 1 according to the Italian Standards UNI VF 8456 and UNI VF 8457.
This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Trevira GmbH
(This document is valid without signature.)

Trevira GmbH, Trademark Service, Max-Fischer-Straße 11, 86399 Bobingen, Germany
E-Mail: trademark.service@trevira.com